

Month	Lift Station Inspection	Year
March		2023

Electric Meter		975	Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	28163		1625.91		1684.53				
3.6.23	28277	114	1628.65	2.74	1698.21	13.68	y		
3.14.23	28409	132	1631.67	3.02	1701.17	2.96	y		
3.21.23	28525	116	1634.42	2.75	1703.82	2.65	y		
3.31.23	28688	163	1638.84	4.42	1708.19	4.37	y		
		525		12.93		23.66			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves #1 #1	
3.6.23	y	y	n	n	y	na	purge	y	y
3.14.23	y	y	n	n	n	na	purge	y	y
3.21.23	y	y	n	n	n	na	purge	y	y
3.31.23	y	y	n	n	n	na	change	y	y
0									

Standby Generator									
Date	Automatic Run as Scheduled	Hour	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
3.6.23	y	288.1	288.1	y	y	12.9	y	good	
3.14.23	y	288.3	0.2	y	y	12.7	n	good	
3.21.23	y	288.5	0.2	y	y	12.9	n	good	
3.31.23	y	288.7	0.2	y	y	12.6	n	good	
0			288.7						

Meter Reading						Change Chart Y/N	
Date	Current Read	Weekly Total	Days	Daily Average			
Previous	259824430						
3.6.23	260031460	207030	7	29576			
3.14.23	260255790	224330	8	28041			
3.21.23	260452820	197030	7	28147			
3.31.23	260749630	296810	10	29681			
0							
Monthly Total		925200	32	28861			