

Month	Lift Station Inspection	Year
April		2023

Electric Meter		28688 ✓	Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous			1638.84		1708.19				
4.8.23	28816	28816	1642.49	3.65	1711.71	3.52	y		
4.16.23	28919	103	1645.77	3.28	1714.77	3.06	y		
4.23.23	29007	88	1648.4	2.63	1717.53	2.76	y		
4.28.23	29076	69	1651.27	2.87	1720.19	2.66	y		
		29076 ✓		12.43		12			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprng/Fall Grease	Lube Filter	Exercise Valves #1 #1	
4.8.23	y	y	n	n	y	na	changed	y	y
4.16.23	y	y	n	n	n	na	purged	y	y
4.23.23	y	y	n	n	n	na	purged	y	y
4.28.23	y	y	n	n	n	na	purged		
0									

Standby Generator									
Date	Automatic Run as Scheduled	Hour	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
4.8.23	y	288.9	288.9	y	y	12.7	y	good	
4.16.23	y	289.1	0.2	y	y	12.8	n	good	
4.23.23	y	289.3	0.2	y	y	12.7	n	good	
4.28.23	y	293.5	4.2	y	y	12.8			
0			293.5						

Meter Reading					Change Chart Y/N
Date	Current Read	Weekly Total	Days	Daily Average	
Previous	260749630				
4.8.23	261022500	272870	8	34109	
4.16.23	261231450	208950	8	26119	
4.23.23	261408610	177160	7	25309	
4.28.23	261542200 ✓	133590	5	26718	
0					
Monthly Total		792570	28 ✓	28064 ✓	