

Month	Lift Station Inspection	Year
MARCH		2022

Electric Meter 1066			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	23504		1466.60		1540.64				
3/3/22	23607	103	1469.04	2.44	1543.02	2.38	y	—	—
3/11/22	23741	237	1472.33	3.29	1546.22	3.20	y	—	—
3/18/22	23854	350	1475.19	2.86	1549.03	2.81	y	—	—
3/31/22	24069	565	1481.06	5.87	1554.75	5.72	y	—	—
	YTD	1671							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
3/3/22	y	y	N	N	N	—	purge	✓	✓
3/11/22	y	y	N	N	y	—	purge	✓	✓
3/18/22	y	y	N	N	N	—	purge	✓	✓
3/31/22	y	y	N	N	N	—	purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
3/3/22	y	273.9	.2	✓	✓	12.7	y	good	
3/11/22	y	274.1	.2	✓	✓	12.8	y	good	
3/18/22	y	274.3	.2	✓	✓	12.6	y	good	
3/31/22	y	274.7	.4	✓	✓	12.6	y	good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	249101220			
3/3/22	249781900	180,680	30,113	N
3/11/22	249526320	244,470	30,533	y
3/18/22	249737670	211,350	30,192	N
3/31/22	250150970	413,300	31,792	y
Monthly Total		1,049,750	30,875	

2/25

Scan