

Month		Lift Station Inspection	Year	
September			2023	

Electric Meter		2905	Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	30093		1699.98		1767.18				
9.7.23	30143	50	1702.83	2.85	1770.5	3.32	y		
9.14.23	30192	49	1705.63	2.8	1773.34	2.84	y		
9.22.23	30245	53	1708.65	3.02	1776.28	2.94	y		
10.3.23	30321	76	1712.8	4.15	1780.33	4.05	y		
		228		12.82		13.15			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves #1 #1	
9.7.23	y	y	n	n	n	na	purge	y	y
9.14.23	y	y	n	n	n	na	purge	n	n
9.22.23	y	y	n	n	n	na	putge	n	n
10.3.23	y	y	n	n	y	na	change	n	n
0									

Standby Generator									
Date	Automatic Run as Scheduled	Hour 293.1	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
9.7.23	y	293.3	0.2	y	y	12.8	y	good	
9.14.23	y	293.5	0.2	y	y	12.7	y	good	
9.22.23	y	293.7	0.2	y	y	12.8	n	good	
10.3.23	y	294.1	0.4	y	y	12.6	n	good	
0			1						

Meter Reading						Change Chart Y/N	
Date	Current Read	Weekly Total	Days	Daily Average			
Previous	264761930						
9.7.23	264917730	155800	7	22257		n	
9.14.23	265117790	200060	7	28580		n	
9.22.23	265309410	191620	8	23953		n	
10.3.23	265590130	280720	11	25520			
0							
Monthly Total		828200	33	25077			

Scar