

# MONTHLY LIFT STATION REPORT

## 205<sup>TH</sup> SEWER LIFT STATION

MONTH November 2021 YEAR

DATES FROM: 10/31 - 12/2

NUMBER OF DAYS: 32 days

Reading: 246376060

Total Flow: 879,080

Average daily flow: 27,471

KW 478

KW Y.T.D.: 4398

ADDED REPAIRS YES SEE ATTACHED  
NO

### COMMENTS:

11/22 pump down tests for flows and headwork

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SIGNATURE Dy McNeill

*Dean*

Month	<b>Lift Station Inspection</b>	Year
NOVEMBER		2021

Electric Meter 3920			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	21477		1414.73		1489.94				
11/9/21	21599	122	1417.78	3.35	1493.22	3.28	Y		
11/22/21	21795	318	1423.12	5.34	1498.44	5.22	Y		
12/2/21	21985	478	1427.29	4.17	1502.48	4.04	Y		
FTD	4398								

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
11/9/21	Y	Y	N	N	Y	-	page	Y	Y
11/22/21	Y	Y	N	N	Y	-	page	Y	Y
12/2/21	Y	Y	N	N	Y	-	page	Y	Y

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
11/9/21	Y	270.7	1.2	Y	Y	12.8	Y	good	
11/22/21	Y	271.1	.4	Y	Y	1	N	good	
12/2/21	Y	271.3	1.2	Y	Y	14.1	N	good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	245496980			
11/9/21	245732580	235,600	9	N
11/22/21	246084120	351,540	13	Y
12/2/21	246376060	291,940	10	Y
Monthly Total		879,080	32	27,471

scan