

MONTHLY LIFT STATION REPORT

205TH SEWER LIFT STATION

MONTH May 2021 YEAR

DATES FROM: 4/29 — 5/30

NUMBER OF DAYS: 31

Reading: 241310250

Total Flow: 878,620

Average daily flow: 28,342

KW 379

KW Y.T.D.: 2349

ADDED REPAIRS YES SEE ATTACHED
NO

COMMENTS:

SIGNATURE My Michael

scan

Month	Lift Station Inspection	Year
MAY		2021

Electric Meter 1970			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	19527		1336.77		1416.64				
5/7/21	19632	105	1340.13	3.36	1419.88	3.24	Y		
5/20/21	19791	264	1345.21	5.08	1424.79	4.91	Y		
5/27/21	19867	340	1348.32	3.11	1427.80	3.01	Y		
5/30/21	19906	379	1349.49	1.17	1428.94	1.14	Y		
YTD		2349		12.72		12.30			

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
5/7/21	Y	Y	-	-	Y	-	purge	✓	✓
5/20/21	Y	Y	-	-	Y	-	purge	✓	✓
5/27/21	Y	Y	-	-	Y	-	purge	✓	✓
5/30/21	Y	Y	-	-	Y	-	purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
5/7/21	Y	231.9	.2	✓	✓	12.6	Y	good	
5/20/21	Y	232.3	.4	✓	✓	14.1	N	good	
5/27/21	Y	232.5	.2	✓	✓	12.7	N	good	
5/30/21	Y	232.5	0	✓	✓	12.7	N	good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	240431030			
5/7/21	240667320	235,690 8	29,468	
5/20/21	241020260	352,940 13	27,149	
5/27/21	241226770	206,510 7	29,501	
5/30/21	241310250	83,480 3	27,827	
Monthly Total		878,620 31	28,342	