



Month	<b>Lift Station Inspection</b>	Year
August		2021

Electric Meter 2948			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	20505		1375.82		1454.4				
8/6/21	20574	69	1379.69	3.87	1458.24	3.63	Y		
8/16/21	20660	155	1384.22	4.64	1460.70	4.46	Y		
8/26/21	20750	245	1388.49	4.16	1464.77	4.07	Y		
YTD		3193							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
8/6/21	Y	Y	N	—	Y	—	purge	Y	Y
8/16/21	Y	Y	N	—	Y	—	purge	Y	Y
8/26/21	Y	Y	N	—	Y	—	purge	Y	Y

<b>Standby Generator</b>									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
8/6/21	Y	234.5	.2	✓	✓	13.9	—	good	
8/16/21	Y	268.3	33.8	✓	✓	12.8	—	good	
8/26/21	Y	268.5	.2	✓	✓	12.6	—	good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	243020610			
8/6/21	243206330	185,720	✓7 26,531	
8/16/21	243498290	291,960	✓10 29,196	
8/26/21	243776440	278,150	✓10 27,815	
Monthly Total		753,830	✓27 27,993	

\* Power outage