

MONTHLY LIFT STATION REPORT

205<sup>TH</sup> SEWER LIFT STATION

MONTH July 2021 YEAR

DATES FROM: 7/1/21 - 7/30/21

NUMBER OF DAYS: 29

Reading: 243020610

Total Flow: 810,360

Average daily flow: 27,943

KW 279

KW Y.T.D.: 2948

ADDED REPAIRS  YES SEE ATTACHED  
NO

COMMENTS:

Water line for bearing plugged on pump #2  
Water filter housing started leaking during repair  
could not be fixed ordered new filter housing  
spare filter end pipe and fitting to replace all  
lines

SIGNATURE My Nellwell

7/1/21

Month	<b>Lift Station Inspection</b>	Year
July		2021

Electric Meter 2669			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	20226								
7/8/21	20246	70	1366.67	1366.69	1445.71	1445.71	y		
7/16/21	20379	153	1370.23	3.54	1449.18	3.47	y		
7/23/21	20445	219	1372.15	2.92	1452.03	2.85	y		
7/30/21	20505	279	1375.82	2.67	1454.61	2.58	y		
YTD		2948							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
7/8/21	y	y	N	N	y	-	purge	✓	✓
7/16/21	y	y	N	N	y	-	purge	✓	✓
7/23/21	y	y	N	N	y	-	purge	✓	✓
7/30/21	y	y	N	N	y	-	purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
7/8/21	y	232.7	.2	✓	✓	12.8	y	good	
7/16/21	y	233.9	.2	✓	✓	12.7	y	good	
7/23/21	y	234.1	.2	✓	✓	12.9	N	good	
7/30/21	y	234.3	.2	✓	✓	12.7	N	good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	242210250			
7/8/21	242416600	206,350 / 7	29,478	
7/16/21	242613490	206,890 / 8	25,361	
7/23/21	242835350	191,860 / 7	27,409	
7/30/21	243020610	185,260 / 7	26,466	
Monthly Total		810,360 / 29	27,943	