

MONTHLY LIFT STATION REPORT

205TH SEWER LIFT STATION

MONTH March 2021 YEAR

DATES FROM: 2/25 thru 4/1

NUMBER OF DAYS: 35

Reading: 239622390

Total Flow: 1,066,190

Average daily flow: 30,463

KW 542

KW Y.T.D.: 1590

ADDED REPAIRS YES SEE ATTACHED
~~NO~~

COMMENTS:

SIGNATURE My Nelson

| | | |
|-----------------------|--------------------------------|---------------------|
| Month <i>MARCH</i> | Lift Station Inspection | Year <i>2021</i> |
|-----------------------|--------------------------------|---------------------|

| Electric Meter <i>1048</i> | | | Pump Hours | | | | Run Pumps | Motor Amp Draw | |
|----------------------------|--------------|-------------|----------------|-------------|----------------|-------------|-----------|----------------|--------|
| Date | Read | Total | # 1 | Hours | # 2 | Hours | Y/N | Pump 1 | Pump 2 |
| Previous | <i>18605</i> | | <i>1311.40</i> | | <i>1392.40</i> | | | | |
| <i>3/11/21</i> | <i>18834</i> | <i>229</i> | <i>1317.35</i> | <i>5.95</i> | <i>1397.90</i> | <i>5.50</i> | <i>y</i> | | |
| <i>3/18/21</i> | <i>18942</i> | <i>337</i> | <i>1319.99</i> | <i>2.64</i> | <i>1400.42</i> | <i>2.52</i> | <i>y</i> | | |
| <i>3/25/21</i> | <i>19042</i> | <i>437</i> | <i>1322.82</i> | <i>2.83</i> | <i>1403.16</i> | <i>2.74</i> | <i>y</i> | | |
| <i>4/1/21</i> | <i>19147</i> | <i>542</i> | <i>1325.52</i> | <i>2.70</i> | <i>1405.15</i> | <i>1.99</i> | <i>y</i> | | |
| YTD | | <i>1590</i> | | | | | | | |

| Date | Fan OK Y/N | Dialer OK Y/N | Heater ON Y/N | Alarm Y/N | Wet Well Checked | Sprg/Fall Grease | Lube Filters | Exercise Valves | |
|----------------|---------------|------------------|------------------|--------------|---------------------|---------------------|-----------------|-----------------|----------|
| | | | | | | | | # 1 | # 2 |
| <i>3/11/21</i> | <i>y</i> | <i>y</i> | <i>-</i> | <i>-</i> | <i>y</i> | <i>-</i> | <i>purge</i> | <i>x</i> | <i>x</i> |
| <i>3/18/21</i> | <i>y</i> | <i>y</i> | <i>-</i> | <i>-</i> | <i>y</i> | <i>-</i> | <i>purge</i> | <i>x</i> | <i>x</i> |
| <i>3/25/21</i> | <i>y</i> | <i>y</i> | <i>-</i> | <i>-</i> | <i>y</i> | <i>-</i> | <i>purge</i> | <i>x</i> | <i>x</i> |
| <i>4/1/21</i> | <i>y</i> | <i>y</i> | <i>-</i> | <i>-</i> | <i>-</i> | <i>-</i> | <i>purge</i> | <i>x</i> | <i>x</i> |

| Standby Generator | | | | | | | | | |
|--------------------------|-------------------------------|-----------------|----------------|--------------|------------------|--------------------|-------------------|----------------------|--|
| Date | Automatic Run as Scheduled | Hour Reading | Total Hours | Oil Level | Coolant Level | Battery Voltage | Manual Run Y/N | Overall Condition | |
| <i>3/11/21</i> | <i>y</i> | <i>236.1</i> | <i>.4</i> | <i>x</i> | <i>x</i> | <i>12.7</i> | <i>x</i> | <i>good</i> | |
| <i>3/18/21</i> | <i>y</i> | <i>230.4</i> | <i>.3</i> | <i>x</i> | <i>x</i> | <i>12.8</i> | | <i>good</i> | |
| <i>3/25/21</i> | <i>y</i> | <i>230.6</i> | <i>.2</i> | <i>x</i> | <i>x</i> | <i>14.0</i> | | <i>good</i> | |
| <i>4/1/21</i> | <i>y</i> | <i>230.8</i> | <i>.2</i> | <i>x</i> | <i>x</i> | <i>12.7</i> | | <i>good</i> | |

| Meter Reading | | | | Change |
|----------------------|-----------------------------|---------------------------|------------------|-----------|
| Date | Current Read | Weekly Total | Daily Average | Chart Y/N |
| Previous | <i>238556200</i> | | | |
| <i>3/11/21</i> | <i>239007400</i> | <i>457,200</i> | <i>14 32,228</i> | <i>y</i> |
| <i>3/18/21</i> | <i>239206480</i> | <i>198,080</i> | <i>17 28,440</i> | <i>N</i> |
| <i>3/25/21</i> | <i>239420730</i> | <i>214,250</i> | <i>17 30,607</i> | <i>y</i> |
| <i>4/1/21</i> | <i>239622390</i> | <i>201,660</i> | <i>17 28,808</i> | <i>N</i> |
| Monthly Total | | <i>1,066,190</i> | <i>35 30,463</i> | |

Recd 5-11-21