

MONTHLY LIFT STATION REPORT

205TH SEWER LIFT STATION

MONTH FEBRUARY 2021 YEAR

DATES FROM: 1/29/21 - 2/25/21

NUMBER OF DAYS: 27 days

Reading: 238 556 200

Total Flow: 946,764

Average daily flow: 35,065

KW 531

KW Y.T.D.: 1048

ADDED REPAIRS YES SEE ATTACHED
NO

COMMENTS:

SIGNATURE *My Milledal*

Month	Lift Station Inspection	Year
FEBRUARY		2021

517 Electric Meter			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	18074		1398.10		1388.88				
2/4/21	18186	112	1300.77	2.67	1381.82	2.58	Y	-	-
2/11/21	18326	253	1304.30	3.53	1385.24	3.42	Y	-	-
2/19/21	18495	421	1308.40	4.10	1389.21	3.97	Y	-	-
2/25/21	18605	531	1311.40	3	1392.40	2.19	Y	-	-
YTD		1048							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprng/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
2/4/21	Y	Y	N	-	Y	-	purge	✓	✓
2/11/21	Y	Y	N	-	N	-	purge	✓	✓
2/19/21	Y	Y	N	-	N	-	purge	✓	✓
2/25/21	Y	Y	N	-	N	-	purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
2/4/21	Y	229.1	.2	✓	✓	12.8	Y	good	
2/11/21	Y	229.3	.2	✓	✓	12.8	N	good	
2/19/21	Y	229.5	.2	✓	✓	12.8	N	good	
2/25/21	Y	229.7	.2	✓	✓	12.6	N	good	

Meter Reading				Change Chart Y/N	
Date	Current Read	Weekly Total	Daily Average		
Previous	237609436				
2/4/21	237800340	190,904	6	31,817	Y
2/11/21	238052646	252,306	7	36,043	N
2/19/21	238344940	292,299	8	36,537	Y
2/25/21	238556200	211,260	6	35,210	N
Monthly Total		946,764	21	35,665	

Recd- 5-11-21