

# MONTHLY LIFT STATION REPORT

## 205<sup>TH</sup> SEWER LIFT STATION

MONTH February 2022 YEAR

DATES FROM: 2/3/22 - 2/25/22

NUMBER OF DAYS: 22

Reading: 249101220

Total Flow: 770,100

Average daily flow: 35,005

KW 418

KW Y.T.D.: 1066

ADDED REPAIRS      YES      SEE ATTACHED  
                                 NO

**COMMENTS:**  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE My McDonald

*scan*

Month	<b>Lift Station Inspection</b>	Year
February		2022

648

Electric Meter			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	23086		1455.80		1530.13				
2/10/22	23214	128	1459.03	3.23	1533.05	2.92	y	—	—
2/18/22	23361	275	1462.73	3.70	1536.39	3.34	y	—	—
2/25/22	23504	418	1466.60	3.87	1540.64	4.25	y	—	—
YTD	—	1066							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
2/10/22	y	y	N	N	y	—	Charge	✓	✓
2/18/22	y	y	N	N	y	—	Purge	✓	✓
2/25/22	y	y	✓	N	y	—	Purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
2/10/22	y	073.3	.3			12.7			
2/18/22	y	273.5	.3			14.5			
2/25/22	y	273.7	.3			12.8			

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	248 331 120			
2/10/22	248 569 955	238,530 / 7	34,118	y
2/18/22	248 842 910	272,900 / 8	34,120	N
2/25/22	249 101 220	258,310 / 7	36,901	y
Monthly Total		770,100 / 22	35,005	

43

Slam