

Month	Lift Station Inspection	Year
May		2023

Electric Meter		1888	Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	29076		1651.27		1720.19				
5.5.23	29168	92	1652.82	1.55	1721.81	1.62	y		
5.11.23	29234	66	1655.05	2.23	1724.1	2.29	y		
5.19.23	29322	88	1658.11	3.06	1727.07	2.97	y		
5.27.23	29411	89	1661.24	3.13	1729.99	2.92	y		
		335		9.97		9.8			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves	
								#1	#1
5.5.23	y	y	na	n	y	na	purged	y	y
5.11.23	y	y	na	n	n	na	purged	y	y
5.19.23	y	y	na	n	n	na	purged	y	y
5.27.23	y	N	na	n	n	na	changed	y	y
0									

Standby Generator

Date	Automatic Run as Scheduled	Hour 289.5	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition
5.5.23	y	289.7	0.2	y	y	12.8	n	good
5.11.23	y	289.9	0.2	y	y	12.6	n	good
5.19.23	y	290.1	0.2	y	y	12.8	n	good
5.27.23	y	290.3	0.2	y	y	12.7	y	good
0			0.8					

Meter Reading					Change Chart Y/N	
Date	Current Read	Weekly Total	Days	Daily Average		
Previous	261542200					
5.5.23	261718020	175820	7	25117		
5.11.23	261871452	153432	6	25572		
5.19.23	262071528	200076	8	25010		
5.27.23	262273940	202412	8	25302		
0						
Monthly Total		731740	29	25250		