

MONTHLY LIFT STATION REPORT  
205<sup>TH</sup> SEWER LIFT STATION

MONTH \_\_\_\_\_ YEAR \_\_\_\_\_

DATES FROM: 12/2/21 - 12/31/21

NUMBER OF DAYS: 29

Reading: 247 226 140

Total Flow: 850,080

Average daily flow: 29,313

KW 483

KWY.T.D.: 4881

ADDED REPAIRS      YES      SEE ATTACHED  
                                 NO

COMMENTS:  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

SIGNATURE Tom McDonald

Month	<b>Lift Station Inspection</b>	Year
December		2021

4398 Electric Meter <del>21955</del>			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	21955		1427.29		1502.48				
12/9/21	22072	117	1430.01	2.72	1505.14	2.66	y		
12/16/21	22184	229	1433.18	3.17	1508.11	2.97	y		
12/23/21	22305	350	1436.26	3.08	1511.16	3.05	y		
12/31/21	22438	483	1439.57	3.31	1514.47	3.31	y		
YTD		483							

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
12/9/21	y	y	N	N	y	-	Changed	✓	✓
12/16/21	y	y	N	N	y	-	Purged	✓	✓
12/23/21	y	y	N	N	y	-	Purged	✓	✓
12/31/21	y	y	N	N	y	-	Purged	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
12/9/21	yes	271.5	.2	✓	✓	12.8	y	good	
12/16/21	yes	271.7	.2	✓	✓	12.7	N	good	
12/23/21	yes	271.9	.2	✓	✓	12.0	N	good	
12/31/21	yes	272.1	.2	✓	✓	12.8	N	good	

Meter Reading				Change Chart Y/N
Date	Current Read	Weekly Total	Daily Average	
Previous	246 376 060			
12/9/21	246 571 950	195,690	7 27,956	y
12/16/21	246 785 060	213,310	7 30,473	N
12/23/21	246 990 690	205,630	7 29,376	y
12/31/21	247 226 140	235,450	8 29,431	N
Monthly Total		850,080	29,313	

Scan