

MONTHLY LIFT STATION REPORT

205th SEWER LIFT STATION

MONTH	December	2022	Year
Dates From:	11.30.22 thru 1.1.23		
Number of Days:	32		
Reading:	258101740		
Total Flow:	1002740		
Average Daily Flow:	31057		
Kilowatts For Month:	556		
Kilowatts YTD:	4394		
MAINTAINED REPAIRS	Yes No	SEE ATTACHED	

COMMENTS:

SIGNATURE:

Thos M. Wilson

SICAN

Month	Lift Station Inspection	Year
December		2022

Electric Meter		3838	Pump Hours				Ran Pumps	Motor Amp Draw	
Date	Read	Total	#1	Hours	#2	Hours	Y/N	Pump 1	Pump 2
Previous	26632		1586.52		1652.23				
12.12.22	26830	198	1591.59	5.07	1662.12	9.89	y		
12.15.22	26882	52	1592.87	1.28	1663.35	1.23	n		
12.28.22	27123	241	1598.89	6.02	1669.25	5.9	y		
1.1.23	27188	65	1600.91	2.02	1671.18	1.93	y		
		556		14.39		18.95			

Date	Fan OK Y/N	Dialer OK Y/N	heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprg/Fall Grease	Lube Filter	Exercise Valves	
								#1	#1
12.12.22	y	y	n	n	y	na	change	y	y
12.15.22	y	y	n	n	n	na	purge	n	n
12.28.23	y	y	n	n	n	na	purge	n	n
1.1.23	y	y	n	n	n	na	purge	n	n
0									

Standby Generator									
Date	Automatic Run as Scheduled	Hour 283.9	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
12.12.22	y	284.3	0.4	y	y	12.9	y	good	
12.15.22	na	284.3	0	y	y	12.8	n	good	
12.28.22	xx	283.3	0	xx	xx	xx	xx	xx	
1.1.23	y	286.1	2.8	y	y	12.7	n	good	
0			3.2						

Meter Reading						Change Chart Y/N	
Date	Current Read	Weekly Total	Days	Daily Average			
Previous	257099000						
12.12.22	257466720	367720	12	30643		n	
12.15.22	257553820	87100	3	29033		y	
12.28.22	257972300	418480	13	32191		n	
1.1.23	258101740	129440	4	32360		y	
0							
Monthly Total		1002740	32	31057			