

Month	<b>Lift Station Inspection</b>	Year
December		2020

4580 Electric Meter			Pump Hours				Run Pumps	Motor Amp Draw	
Date	Read	Total	# 1	Hours	# 2	Hours	Y/N	Pump 1	Pump 2
Previous	17083		1472.60		1354.54				
12/11/20	17098	145	1276.48	3.88	1358.27	3.73	Y	-	-
12/18/20	17347	264	1279.62	3.14	1361.35	3.08	Y	-	-
12/24/20	17449	366	1282.32	2.69	1363.99	2.64	Y	-	-
12/30/20	17557	474	1285.03	2.71	1366.59	2.60	Y	-	-
YTD		5,054		12.43		12.05			

Date	Fan OK Y/N	Dialer OK Y/N	Heater ON Y/N	Alarm Y/N	Wet Well Checked	Sprng/Fall Grease	Lube Filters	Exercise Valves	
								# 1	# 2
12/11/20	Y	Y	N	-	Y	-	purge	✓	✓
12/18/20	Y	Y	N	-	N	-	purge	✓	✓
12/24/20	Y	Y	N	-	Y	-	purge	✓	✓
12/30/20	Y	Y	N	-	N	-	purge	✓	✓

Standby Generator									
Date	Automatic Run as Scheduled	Hour Reading	Total Hours	Oil Level	Coolant Level	Battery Voltage	Manual Run Y/N	Overall Condition	
12/11/20	Y	227.7	.2	✓	✓	12.8	N	GOOD	
12/18/20	Y	227.9	.2	✓	✓	12.8	N	GOOD	
12/24/20	N	227.9	0	✓	✓	14.0	Y	GOOD	
12/30/20	Y	228.1	.2	✓	✓	12.8	Y	GOOD	

Date	Meter Reading			Change Chart Y/N
	Current Read	Weekly Total	Daily Average	
Previous	235825160			
12/11/20	236088160	263,000	29,222	Y
12/18/20	236309763	221,603	31,657	N
12/24/20	236499710	189,997	31,657	Y
12/30/20	236690350	190,640	31,773	N
Monthly Total		865,190	30,899	