

# MONTHLY LIFT STATION REPORT

## 205th SEWER LIFT STATION

MONTH December 2023 Year

Dates From: 11/28/23 - 1/2/24

Number of Days: 35 days

Reading: 267892200

Total Flow: 1,308,370

Average Daily Flow: 37,382

Kilowatts For Month: 352

Kilowatts YTD: 3862

ADDED REAIRS

Yes

NO

SEE ATTACHED

### COMMENTS:

Could not make entry on 12/31/23 air ventilation fan  
would not turn on had to wait until 1/2/24 to  
~~bring~~ borrow an air tester from the City to  
check air quality - switch is burned up new  
switch on order at Medlar electric

SIGNATURE:

Thos Wilson

PAYROLL SUMMARY FOR

Troy McDonald

MONTH OF *December*

YEAR *2023*

DATE	LOCATION	HOURS	RATE	AMOUNT	NOTES
<i>12/1-12/31</i>	<i>205th Lift Station</i>	<i>Salary</i>	<i>624.16</i>		<i>Monthly Maintenance</i>
<i>12/31</i>	<i>205th Lift Station</i>	<i>Salary</i>	<i>—</i>	<i>—</i>	<i>could not make entry for will not turn on will have to wait until 1/2/24 to get an air tester to make entry</i>

*\$ 624.16* *Troy McDonald*